

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010250  
DATE: 06/01/2010  
CERTIFICATION PROGRAM: Structural  
COMPANY: USA Shutter  
CODE: U-1040-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
USA Shutter Company, LLC 1450 Rail Head Boulevard Naples, FL 34110	Series "Hurricane Abatement System"  Configuration: O Fabric Type: Aramid Fiber and Stainless Steel  Overall Size: W-6782mm(267") H-3353mm(132")

SPECIFICATION	PRODUCT RATING
ASTM E330-02 ASTM E1886-05/E1996-05	Design Pressure: +62/-62 psf Wind Zone 4-Missile Level D

Product Tested By: Fenestration Testing Laboratory, Inc.  
Report No: File No. 09-628/5953/08-1448  
Expiration Date: August 31, 2013

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**


4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI006990  
**DATE:** 03/01/2007  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** USA Shutter  
**CODE:** U-1040-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at [www.NAMICertification.com](http://www.NAMICertification.com). Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>USA Shutter Company, LLC</b> <b>1455 Rail Head Boulevard, Unit 6</b> <b>Naples, FL 34110</b>	<b>Series "MaestroShield® Maestran™"</b> <b>Security Shield Hurricane Barrier</b>  Configuration: O  Material: Mesh w/1500 Denier Aramid Fiber Core  Overall Size:      W-8'4"      H-7'11"

SPECIFICATION	PRODUCT RATING
ASTM E330-02 TAS 201/202/203-94 ASTM E1886-05/E1996-05b	<b>Design Pressure: +70/-70 psf</b> <b>Large Missile Impact Rated</b> <b>Wind Zone 4-Missile Level D</b>

Product Tested By: Hurricane Test Laboratory, LLC  
 Report No: 0432-0115-07  
 Expiration Date: **February 28, 2011**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 11870 Merchants Walk Suite 202  
 Newport News, VA 23606  
 TEL: (757) 594-8658  
 FAX: (757) 594-8659